



August 11, 2008
Addendum #1

TO: ALL BIDDERS

RE: IFB #-006-0-2008/AB – BOILER AND PUMP REPLACEMENT AT HUNTINGTON MIDDLE SCHOOL

1. The above referenced IFB is hereby amended and clarified as follows:
 - a. On page 5 of 16 of the IFB, §I, ¶B.3., revise this sentence as follows: “Work under this contract must be certified as substantially complete no later than **October 10, 2008.**”
 - b. On the Bid Form, revise the second paragraph as follows: “The undersigned understands that time is of the essence and agrees that the date for Substantial Completion of the entire project shall be **October 10, 2008.**”
 - c. In reference to page 15010-6, §2.5, ¶I, revise the first sentence as follows: “All starters and controls shall be NEMA rated and NEMA I enclosed. Interior starters do not need to be NEMA 4X (stainless), but instead should be NEMA 3R.”
 - d. On page 15900-2, ¶1.4E, last sentence, delete “Chesapeake Controls, Inc.” and revise the sentence as follows: “*Dominion Energy Management* is the only acceptable contractor.”
 - e. **Attachments B through F** are hereby incorporated into this IFB and resulting contract and includes revisions to the number of temperature sensors required, as well as the location of the temperature sensors.
 - f. As a result of this addendum, the **Bid Opening date is extended to Friday, August 15, 2008, at 1:30PM.**
2. All other provisions of the IFB shall remain unchanged. This provision shall become part of the IFB package, and Bidder shall acknowledge receipt of the Addendum by signing in the space provided below and returning it with the Bid.

Signature: _____
(Bidder)

Sincerely,

Angela Bright, CPPB
Purchasing Coordinator