

4.2 POINTS LIST

Point Name	HARDWARE														NOTES		
	OUTPUT							INPUT									
	DIGITAL				ANALOG			DIGITAL				ANALOG					
	CONTROL RELAY	START/STOP	TWO POSITION ACTUATOR		MODULATING ACTUATOR			STATUS POSITION	STATUS ALARM		SUPPLY WATER TEMP	RETURN WATER TEMP	BOILER WATER TEMP				
Boiler Room No. 1																	
HOT WATER PUMP-1	1							1	1								
HOT WATER PUMP-2	1							1	1								
HOT WATER PUMP-3	1							1	1								
HOT WATER PUMP-5	1							1	1								
HOT WATER PUMP-6	1							1	1								
BOILER-1	1								1								
BOILER-2	1								1								
HOT WATER RESET VALVE					1												
SYSTEM SUPPLY TEMP										1							
SYSTEM RETURN TEMP											1						
BOILER SUPPLY TEMP												1					Typical of 2
Boiler Room No. 2																	
HOT WATER PUMP-5	1							1	1								
HOT WATER PUMP-6	1							1	1								
HOT WATER PUMP-7	1							1	1								
HOT WATER PUMP-8	1							1	1								
HOT WATER PUMP-9	1							1	1								
HOT WATER PUMP-10	1							1	1								
HOT WATER PUMP-11	1							1	1								
HOT WATER PUMP-12	1							1	1								
HOT WATER PUMP-13	1							1	1								
BOILER-3	1								1								
BOILER-4	1								1								
HOT WATER RESET VALVE					1												
SYSTEM SUPPLY TEMP										1							
SYSTEM RETURN TEMP											1						
BOILER SUPPLY TEMP												1					Typical of 2
Boiler Room No. 3																	
HOT WATER PUMP-1	1							1	1								
HOT WATER PUMP-2	1							1	1								
HOT WATER PUMP-3	1							1	1								
HOT WATER PUMP-4	1							1	1								
BOILER-5	1								1								
BOILER-6	1								1								
HOT WATER RESET VALVE					1												
SYSTEM SUPPLY TEMP										1							
SYSTEM RETURN TEMP											1						
BOILER SUPPLY TEMP												1					Typical of 2

